



CTC 32-bit Data Communications Functions Reference Guide

Doc. No. MAN-1080A

Contents

Notes to Readers	iv
1 Using CTC's Data Communications Functions	1-1
CTC Data Communications Functions	1-2
Introduction	1-2
Installing the DLL Functions	1-2
Function Overview	1-3
Using the Functions in a Visual Basic Program	1-5
Using the Functions in a C++ Program	1-7
2 Function Descriptions	2-1
Network Access Functions	2-2
CtOpenConnection	2-2
CtInitConnection	2-3
CtCloseConnection	2-4
CtSetConnectionTimeout	2-5
Register Functions	2-6
CtGetRegister	2-6
CtGetRegister16	2-7
CtGetRegister50	2-8
CtPutRegister	2-9
Flag Functions	2-10
CtGetFlag	2-10
CtPutFlag	2-11
Digital I/O Functions	2-12
CtGetDigitalInput8	2-12
CtGetDigitalOutput8	2-13
CtGetDigitalInput128	2-14
CtGetDigitalOutput128	2-15
Analog I/O Functions	2-16
CtGetAnalogInput	2-16
CtGetAnalogOutput	2-17
CtPutAnalogOutput	2-18
CtGetAnalogInput32	2-19
CtGetAnalogOutput32	2-20

Servo Functions	2-21
CtGetServoPosition	2-21
CtGetServoError	2-22
CtGetServoInputs	2-23
Data Table Functions	2-24
CtGetDataTableDim	2-24
CtGetDataTableLoc	2-25
CtPutDataTableLoc	2-26
CtGetDataTableRow	2-27
CtPutDataRow	2-28
Controller Status Functions	2-29
CtGetStatus	2-29
CtPutStatus	2-30
CtGetTaskBank	2-31
Controller Configuration Functions	2-33
CtGetModel	2-33
CtGetConfig	2-34
CtPutConfig	2-35
CtGetIoCount	2-36
CtGetMiscIoCount	2-37
Programming Functions	2-38
CtDownload	2-38
CtUpload	2-39
Miscellaneous Functions	2-40
CtGetConnectionInfo	2-40
CtGetMessageInfo	2-41
CtGetErrorInfo	2-42

Notes to Readers

The *CTC 32-bit Data Communications Functions Reference Guide* describes the CTC's DLL functions used to communicate with a controller. These functions are available in a Dynamic-link Library (DLL) that can be used with 32-bit programs such as Visual Basic or C++ program.

Related Documents

The following documents contain additional information

- For information on the registers in your controller, refer to *Register Reference Guide* available on the Web site.
- For information on your controller and its modules, refer to the appropriate Installation and Applications Guide.
- For information on Microsoft Windows or your PC, refer to the manuals provided by the vendor.

Book Conventions

The following conventions are used in this book.

ALL CAPS BOLDFACE	Identifies field lengths in the DLL functions.
Boldface	Identifies DLL function names.
<i>Italics</i> and <i>Boldface Italics</i>	Indicates DLL parameters
<i>Italics</i>	Indicates a word requiring an appropriate substitution. For example, replace <i>filename</i> with an actual file name.
<code>Courier font</code>	Identifies Visual Basic and C+ programming examples.

How to Contact Control Technology Corporation

Control Technology Corporation is located in Massachusetts, and we are open from 8:30 a.m. to 5:00 p.m. eastern time. Contact us at 1-508-435-9595 and 1-800-282-5008 or FAX 1-508-435-2373.

See us on the World Wide Web: <http://www.control.com/>.

Your Comments

We welcome your suggestions and comments about this or any other Control Tech document. You can email comments about this manual or any other CTC document to techpubs@control.com.

Document Notice

The information in this document is subject to change without notice. The software described in this document is provided under license agreement and may be used or copied only in accordance with the terms of the license agreement.

The information, drawings, and illustrations contained herein are the property of Control Technology Corporation. No part of this manual may be reproduced or distributed by any means, electronic or mechanical, for any purpose other than the purchaser's personal use, without the express written consent of Control Technology Corporation.

The following are trademarks of Control Technology Corporation:

- Quickstep
- CTC Monitor

MS-DOS and Windows are trademarks of Microsoft Corporation

Using CTC's Data Communications Functions

Contents

CTC Data Communications Functions	1-2
Function Overview	1-3
Using the Functions in a Visual Basic Program	1-5
Using the Functions in a C++ Program	1-7

CTC Data Communications Functions

Introduction

Control Technology Corp. (CTC) provides two programs, CTC Monitor and CTC Utilities for Windows, for communicating with your controller. These programs are Windows applications and are suitable for most controller-computer communications. However, there are some applications where you may want to create your own program to communicate with the controller. For such cases, we have made available a group of communications functions in a Dynamic-link Library (DLL) that can be used with 32-bit programs such as Visual Basic or C++ program.

The CTC data communications functions are available from the customer section of the Control Technology web site. The self-extracting installation file, *Ctccom32v2.exe*, contains the following files:

- *Ctccom32v2.dll*: The DLL communications functions file
- *Ctccom32v2.h*: C header file containing the DLL function declarations
- *Ctccom32v2.bas*: Visual Basic 4.0/5.0/6.0 code module
- *Ctccom32v2.lib*: C library file
- *Ctccom32v2.pdf*: Ctccom32v2 function reference documentation file in Acrobat pdf format
- *Readme.txt*: Readme file

Installing the DLL Functions

To install the DLL functions,

1. Down load the *Ctccom32v2.exe* to your computer from the web site.
2. Select **Run** from the **Start** menu on the **Taskbar**.
3. Enter the path location of the *Ctccom32v2.exe* file.
4. When the installation program prompts you, enter a location for the files.
5. Once you have run the installation program, make sure you place the *Ctccom32v2.dll* in the appropriate windows directory:
 - Windows 95 users copy the *Ctccom32v2.dll* file to your *Windows\System* directory
 - Windows NT the users copy *Ctccom32v2.dll* to your *Windows\System32* directory
 - Windows 98 the users copy *Ctccom32v2.dll* to your *Windows\System32* directory

Function Overview

The following table lists each function and briefly describes it. For a complete description of each function, see chapter 2, *Function Descriptions*.

CTC Communications Functions

Network Access Functions

CtOpenConnection	Opens a serial, CTC ethernet, or CTC web connection to a controller
CtInitConnection	Initializes an open serial connection to a controller
CtCloseConnection	Closes a connection to a controller
CtSetConnectionTimeout	Sets a time-out value for computer-controller connection response time

Register Functions

CtGetRegister	Reads the current value of a register
CtGetRegister16	Reads the current values in a block of 16 contiguous registers.
CtGetRegister50	Reads the current values of a block of 50 contiguous registers
CtPutRegister	Writes a new value to a register

Flag Functions

CtGetFlag	Reads the value of the flags (1 - 32) in the controller
CtPutFlag	Writes a new value to a flag

Digital I/O Functions

CtGetDigitalInput8	Reads the values of a bank of eight digital inputs
CtGetDigitalOutput8	Reads the values of a bank of eight digital outputs
CtGetDigitalInput128	Reads the values of a bank of 128 digital inputs
CtGetDigitalOutput128	Reads the values of a bank of 128 digital outputs

Analog I/O Functions

CtGetAnalogInput	Reads the value of an analog input
CtGetAnalogOutput	Reads the value of an analog output
CtPutAnalogOutput	Writes a value to an analog input
CtGetAnalogInput32	Reads the values of a bank of 32 analog inputs
CtGetAnalogOutput32	Reads the values of a bank of 32 analog outputs

Servo Functions

CtGetServoPosition	Reads the current position of a servo
CtGetServoError	Reads the current error of a servo
CtGetServoInputs	Reads the value of servo inputs

Data Table Functions

CtGetDataTableDim	Reads the dimensions of the data table
CtGetDataTableLoc	Reads a value at a location in the data table
CtPutDataTableLoc	Writes a value to a location in the data table
CtGetDataTableRow	Reads the values in a data table row
CtPutDataTableRow	Writes values to a row in a data table

Controller Status Functions

CtGetStatus	Reads the controller status
CtPutStatus	Sets the controller status
CtGetTaskBank	Reads a program status task bank from the controller

CTC Communications Functions (Continued)

Controller Configuration Functions

CtGetModel	Reads the controller model information
CtGetConfig	Reads the controller configuration
CtPutConfig	Sets the controller configuration
CtGetIoCount	Reads the basic hardware configuration of a controller
CtGetMiscIoCount	Reads the extended hardware configuration of a controller

Data Table Functions

CtGetDataTableDim	Reads the dimensions of the data table
CtGetDataTableLoc	Reads a value at a location in the data table
CtPutDataTableLoc	Writes a value to a location in the data table
CtGetDataTableRow	Reads the values in a data table row
CtPutDataTableRow	Writes values to a row in a data table

Controller Status Functions

CtGetStatus	Reads the controller status
CtPutStatus	Sets the controller status
CtGetTaskBank	Reads a program status task bank from the controller

Controller Configuration Functions

CtGetModel	Reads the controller model information
CtGetConfig	Reads the controller configuration
CtPutConfig	Sets the controller configuration
CtGetIoCount	Reads the basic hardware configuration of a controller
CtGetMiscIoCount	Reads the extended hardware configuration of a controller

Programming Functions

CtDownload	Downloads an object file into the controller
CtUpload	Uploads the controller's program to an object file

Miscellaneous Functions

CtGetConnectionInfo	Returns information on the connection
CtGetMessageInfo	Returns information on the last message sent and last response received for the connection
CtGetErrorInfo	Returns information on the last error condition for the connection

Programming Functions

CtDownload	Downloads an object file into the controller
CtUpload	Uploads the controller's program to an object file

Miscellaneous Functions

CtGetConnectionInfo	Returns information on the connection
CtGetMessageInfo	Returns information on the last message sent and last response received for the connection
CtGetErrorInfo	Returns information on the last error condition for the connection

Using the Functions in a Visual Basic Program

When using the CTC communications functions in a Visual Basic program, you must insert the *Ctccom32v2.bas* file into your Visual Basic project. Once the *Ctccom32v2.bas* file has been inserted into your project, a number of useful constants are defined as well as the function definitions for the DLL. The following list is a subset of the function definitions in the *Ctccom32v2.bas* file. For a complete list of functions definitions, see Chapter 2, *Function Descriptions*.

```
` network access functions
Declare Function CtOpenConnection Lib "Ctccom32v2.dll" _
    (ByVal ConnectID As Long, ByVal CommPort As Long, _
    ByVal Address As Long) As Long
Declare Function CtInitConnection Lib "Ctccom32v2.dll" _
    (ByVal ConnectID As Long, ByVal BaudRate As Long, _
    ByVal Parity As Byte, ByVal DataBits As Byte, _
    ByVal StopBits As Byte) As Long
Declare Function CtCloseConnection Lib "Ctccom32v2.dll" _
    (ByVal ConnectID As Long) As Long
Declare Function CtSetConnectionTimeout Lib _
    "Ctccom32v2.dll" (ByVal ConnectID As Long, _
    ByVal MilliSeconds As Long) As Long

` register functions
Declare Function CtGetRegister Lib "Ctccom32v2.dll" _
    (ByVal ConnectID As Long, ByVal RegAddress _
    As Long, ByRef RegValue As Long) As Long
Declare Function CtGetRegister16 Lib "Ctccom32v2.dll" _
    (ByVal ConnectID As Long, ByVal RegAddress _
    As Long, ByRef Reg16Val As Long) As Long
Declare Function CtGetRegister50 Lib "Ctccom32v2.dll" _
    (ByVal ConnectID As Long, ByVal RegBank As Long, _
    ByRef Reg50Val As Long) As Long
Declare Function CtPutRegister Lib "Ctccom32v2.dll" _
    (ByVal ConnectID As Long, ByVal RegAddress _
    As Long, ByVal RegValue As Long) As Long
```

To use the functions, the user must first establish a connection to a CTC controller. The following code opens a serial connection on COM1:

```
Dim lType as long
Dim lLocal as long
Dim lRemote as long
Dim lConnectID as long
lType = SERIAL
lLocal = 1
lRemote = 0
lConnectID = CtOpenConnection(lType, lLocal, lRemote)
```

If the connection is opened, a non-zero number is returned. This number represents is connection identifier and will be used in all subsequent calls to the DLL functions. The following Visual Basic code sets the time-out in milliseconds for the connection:

```
Dim lTimeout as long
`set timeout
lTimeout = 500
If CtSetConnectionTimeout(lConnectID, lTimeout) = FAILURE
Then
    MsgBox "Failed to set timeout.", vbExclamation
End If
```

Once a connection has been opened you can call functions to read and write register data. In the examples shown here, the program includes a text box control named *Text1.Text* to display one of the register values obtained by the function. The *Format\$* function converts a long integer to a string for the display.

```
Dim lValue as long
Dim lAddress as long
lAddress = 13002
If CtGetRegister(lConnectID, lAddress, lValue) <> SUCCESS
Then
    MsgBox "Failed to get register.", vbExclamation
Else
    'update display
    Text1.Text = Format$(lValue)
End If

Dim lValue(0 to 15) as long
lAddress = 13002
If CtGetRegister16(lConnectID, lAddress, lValue(0)) <>
SUCCESS Then
    MsgBox "Failed to get 16 registers.", vbExclamation
Else
    'update display
    Text1.Text = Format$(lValue(0))
End If

Dim lBank as long
Dim lValue(1 to 50) as long
lBank = 1
If CtGetRegister50(lConnectID, lBank, lValue(1)) <>
SUCCESS Then
    MsgBox "Failed to get 50 registers.", vbExclamation
Else
    'update display
    Text1.Text = Format$(lValue(1))
End If

lAddress = 1
lValue = 12345
'put value
If CtPutRegister(lConnectID, lAddress, lValue) <> SUCCESS
Then
    MsgBox "Failed to put register.", vbExclamation
End If
```

Once finished with communications, you must close any open connection(s). The following code shows how to close a connection:

```
If CtCloseConnection(lConnectID) = 0 Then
    MsgBox "Failed to close connection", vbExclamation
Else
    lConnectID = 0
End If
```

NOTE: CTC recommends that you check the return value from the function to determine success or failure. These examples use the Visual Basic MsgBox function to display a message in a dialog box in the event of a failure.

Using the Functions in a C++ Program

When using the CTC communications functions in a C+ program, you need to perform a series of declarations in your C program.

1. Declare data types for the functions in the DLL
2. Declare variables of the types defined previously
3. Call LoadLibrary to confirm the file exists and to load it
4. Call GetProcAddress to map the location of the functions in the DLL
5. Call the functions as needed
6. Close the connection(s) and free the library

The following program code shows how to declare data types for the functions in the DLL

```
// ctccom32v2 functions
typedef UINT32 (*CTOPEN)(UINT32, UINT32, UINT32);
typedef UINT32 (*CTINIT)(UINT32, UINT32, UCHAR, UCHAR,
UCHAR);
typedef UINT32 (*CTCLOSE)(UINT32);
typedef UINT32 (*CTSTIME)(UINT32, UINT32);
typedef UINT32 (*CTGETREG)(UINT32, UINT32, INT32 FAR*);
typedef UINT32 (*CTGETREG16)(UINT32, UINT32, REGS_16
FAR*);
typedef UINT32 (*CTGETREG50)(UINT32, UINT32, REGS_50
FAR*);
typedef UINT32 (*CTPUTREG)(UINT32, UINT32, INT32);
```

The following examples shows how to declare variables for the types defined above.

```
INT32          CtLibInst = 0;
CTOPEN        CtOpenConnection;
CTINIT        CtInitConnection;
CTCLOSE       CtCloseConnection;
CTSTIME       CtSetConnectionTimeout;
CTGETREG      CtGetRegister;
CTGETREG16    CtGetRegister16;
CTGETREG50    CtGetRegister50;
CTPUTREG      CtPutRegister;
```

The following example calls LoadLibrary to confirm the file exists and to load it. It then calls **GetProcAddress** to map the location of the functions in the DLL.

```
/* Get a handle to the DLL functions */
if ( CtLibInst == 0 ) {
    if ( ( CtLibInst = LoadLibrary("ctccom32v2.dll") ) !=
(INT32) NULL) {
        CtOpenConnection = (CTOPEN)
GetProcAddress(CtLibInst, "CtOpenConnection");
        CtInitConnection = (CTINIT)
GetProcAddress(CtLibInst, "CtInitConnection");
        CtCloseConnection = (CTCLOSE)
GetProcAddress(CtLibInst, "CtCloseConnection");
        CtSetConnectionTimeout = (CTSTIME)
GetProcAddress(CtLibInst, "CtSetConnectionTimeout");
        CtGetRegister = (CTGETREG)
GetProcAddress(CtLibInst, "CtGetRegister");
        CtGetRegister16 = (CTGETREG16)
```

```
GetProcAddress(CtLibInst, "CtGetRegister16");
    CtPutRegister = (CTPUTREG)
GetProcAddress(CtLibInst, "CtPutRegister");
    CtGetErrorInfo = (CTERROR)
GetProcAddress(CtLibInst, "CtGetErrorInfo");
    }
}
```

The following are examples of function calls in a program.

```
if (( conn = CtOpenConnection(CTNET, host, target)) !=
FAILURE) {
    // set connection timeout
    (void) CtSetConnectionTimeout(conn, timeout);
}

if ( CtGetRegister(conn, address, &result) == SUCCESS) {
    // Set the appropriate state and response buffer
    data = result;
}
```

When you are finished using the DLL functions, close the connection(s) and free the library.

```
if ( CtCloseConnection( conn) != SUCCESS) {
    (void) CtGetErrorInfo( conn, &CtErr);
    sprintf (szAlm, "Couldn't close connection, err
%d.", CtErr.iErrCode);
}

// Free the DLL module
if ( CtLibInst != 0 ) {
    if ( FreeLibrary(CtLibInst) == 0) {
        LastError = GetLastError();
        sprintf (szAlm, "Couldn't unload
CTCCOM32V2.DLL %d.", LastError);
    } else
        CtLibInst = 0;
}
```

Function Descriptions

Contents

Network Access Functions	2-2
Register Functions	2-6
Flag Functions	2-10
Digital I/O Functions	2-12
Analog I/O Functions	2-16
Servo Functions	2-21
Data Table Functions	2-24
Controller Status Functions	2-29
Programming Functions	2-38
Miscellaneous Functions	2-40

Network Access Functions

CtOpenConnection

CtOpenConnection opens a serial, CTC ethernet, or CTC web connection to a controller. Your program must call **CtOpenConnection** once to establish the connection. The connection, once established, remains in use until your program calls **CtCloseConnection**.

When making CTC ethernet connections, use a unique local node address for each connection that communicates with the same remote controller. When making CTC web connections, use a unique local port number. Port numbers from one to 1024 are reserved. Port numbers beginning at 4000 are suggested.

For CTC ethernet connections, the remote node address is the node number in register 20,000 of the controller.

The format for calling **CtOpenConnection** is as follows:

```
ULONG CtOpenNetwork(  
    ULONG      IConnectionType  
    ULONG      ILocalAddress  
    ULONG      IRemoteAddress );
```

Input Parameters

IConnectionType

IConnectionType is a long integer that specifies the type of network connection to open. The allowable values are zero for no connection, one for serial connection, two for CTC ethernet connection, or 3 for a CTC web connection.

ILocalAddress

ILocalAddress is a long integer that specifies the address to use for the connection. The allowable values are a valid serial port number for a serial connection, a valid CTC network node number (1 to 32767) for an ethernet connection, or a valid port number for a CTC web connection.

IRemoteAddress

IRemoteAddress is a long integer that specifies the address of the controller you wish to connect to. The allowable values are a valid CTC network node number (1 to 32767) for an ethernet connection or an IP address for a CTC web connection. Specify zero (not used) when making a serial connection.

Success/Error Return Values

If the function succeeds, the return value is the connection number used with subsequent function calls.

Other Related Functions

CtInitConnection, CtCloseConnection, CtSetConnectionTimeout

CtInitConnection

CtInitConnection initializes an open serial connection to a controller. A program only needs to call **CtInitConnection** when you want to change the default serial communications values established at the time the connection is opened. The default serial port parameters are 9600 baud, no parity, eight data bits, and one stop bit.

The format for calling **CtInitConnection** is as follows:

```
ULONG CtInitConnection (  
    ULONG      lConnectID  
    DWORD      dwBaudRate  
    BYTE       bParity  
    BYTE       bDataBits  
    BYTE       bStopBits );
```

Input Parameters

lConnectID

lConnectID is a long integer value that specifies the connection to initialize.

dwBaudRate

dwBaudRate is a double word value that specifies the baud rate of the serial connection. The default value for CTC controllers is 9600; other allowable values are controller dependent.

bParity

bParity is a byte value that specifies the parity used. The only allowable value is zero (no parity).

bDataBits

bDataBits is a byte value that specifies the number of data bits used. The only allowable value is eight (eight data bits used).

bStopBits

bStopBits is a byte value that specifies the number of stop bits used. The only allowable value is zero (one stop bit used).

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtOpenConnection, CtCloseConnection, CtSetConnectionTimeout

CtCloseConnection

CtCloseConnection closes a connection to a controller. This command needs to be issued once for each connection.

The format for calling **CtCloseConnection** is as follows:

```
ULONG CtCloseConnection (  
    ULONG      IConnectID );
```

Input Parameters

IConnectID

IConnectID is a long integer value that specifies the connection to close.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtOpenConnection, CtInitConnection, CtSetConnectionTimeout

CtSetConnectionTimeout

The **CtSetConnectionTimeout** function is used by all functions in communication with the controller. If a response is not obtained within the time specified by the time-out value, the function reports an error.

The format for calling **CtSetConnectionTimeout** is as follows:

```
ULONG CtSetConnectionTimeout (  
    ULONG      lConnectD  
    ULONG      lMilliseconds );
```

Input Parameters

lConnectD

lConnectD is a long integer that specifies the connection to change.

lMilliseconds

lMilliseconds is a long integer that specifies the number of milliseconds to wait for a response before timing out. The default value is 250 milliseconds.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtOpenConnection, CtInitConnection, CtCloseConnection

Register Functions

CtGetRegister

CtGetRegister reads the current value of a register.

The format for calling **CtGetRegister** is as follows:

```
ULONG CtGetRegister (  
    ULONG      IConnectID  
    ULONG      IRegister  
    LPLONG     pValue );
```

Input Parameters

IConnectID

IConnectID is a long integer that specifies the connection to use.

IRegister

IRegister is a long integer that specifies the register address.

Output Parameters

pValue

pValue points to a long integer that receives the value of the register.

The register value returned to the *pValue* pointer is a number from -2,147,483,647 to 2,147,483,647.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetRegister16, CtGetRegister50, CtPutRegister

CtGetRegister16

CtGetRegister16 reads the current values in a bank of 16 contiguous registers. You must specify the number of the first register in the block.

The format for calling **CtGetRegister16** is as follows:

```
ULONG CtGetRegister16 (  
    ULONG      lConnectID  
    ULONG      lRegister  
    REGS_16 *  pValues );  
  
Typedef ULONG REGS_16[16];
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lRegister

lRegister is a long integer that specifies the starting register address.

Output Parameters

pValues

pValues points to a 16-element array of long integers that receives the register values.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetRegister, CtGetRegister50, CtPutRegister

CtGetRegister50

CtGetRegister50 reads the current values of a bank of 50 contiguous registers. Using this function you can read registers one to 1000, by specifying the bank number (1 to 20) of the registers. Bank one contains registers one - 50, bank two contains registers 51 - 100, up to bank 20, which is for registers 951 to 1000.

The format for calling **CtGetRegister50** is as follows:

```
ULONG CtGetRegister50 (  
    ULONG      lConnectID  
    ULONG      lBank  
    REGS_50 *  pValues );
```

```
Typedef ULONG REGS_50[50];
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lBank

lBank is a long integer that specifies the bank number.

Output Parameters

pValues

pValues points to a 50-element array of long integers that receives the register values.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetRegister, CtGetRegister16, CtPutRegister

CtPutRegister

CtPutRegister writes a new value to a register. Values can range from -2,147,483,647 to 2,147,483,647.

The format for calling **CtPutRegister** is as follows:

```
ULONG CtPutRegister (  
    ULONG      lConnectID  
    ULONG      lRegister  
    LONG       lValue );
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lRegister

lRegister is a long integer that specifies the register address.

Output Parameters

lValue

lValue is a long integer that specifies the new register value to write.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetRegister, CtGetRegister16, CtGetRegister50

Flag Functions

CtGetFlag

CtGetFlag reads the value of the flags (1 - 32) in the controller.

The format for calling **CtGetFlag** is as follows:

```
ULONG CtGetFlag (  
    ULONG      lConnect  
    ULONG      lFlag  
    LPLONG     pValue );
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lFlag

lFlag is a long integer that specifies the flag number.

Output Parameters

pValue

pValue points to a long integer that receives the value of the flag.

If a flag is clear, the returned value is zero, and if set, the returned value is one.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtPutFlag

CtPutFlag

The **CtPutFlag** function writes a new value to a flag. You can set or clear any flag (1 to 32). To set a flag, specify any positive number, and to clear the flag, enter any negative value or zero.

The format for calling **CtPutFlag** is as follows:

```
ULONG CtPutFlag(  
    ULONG      IConnect  
    ULONG      IFlag  
    ULONG      IValue );
```

Input Parameters

IConnectID

IConnectID is a long integer that specifies the connection to use.

IFlag

IFlag is a long integer that specifies the flag number to update.

IValue

IValue is a long integer that specifies the new flag value to write

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetFlag

Digital I/O Functions

CtGetDigitalInput8

The **CtGetDigitalInput8** function reads the values of a bank of eight digital inputs. Using this function you can read digital inputs in groups of eight by specifying the bank number. Bank number one is for inputs one to 8; bank two for inputs nine to 16, and so on.

The format for calling **CtGetDigitalInput8** is as follows:

```
ULONG CtGetDigitalInput8 (  
    UULONG    lConnectID  
    ULONG     lBank  
    LPLONG    pValues );
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lBank

lBank is a long integer that specifies the bank number of the block of eight digital inputs.

Output Parameters

pValues

pValues points to a long integer that receives the value of the eight digital inputs.

The return value for the inputs is the bit mask of the block of eight inputs. The lower eight bits of the long integer contains the block of eight digital inputs.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetDigitalOutput8, CtGetDigitalInput128, CtGetDigitalOutput128

CtGetDigitalOutput8

CtGetDigitalOutput8 reads the value of a block of eight digital outputs. Using this function you can read digital outputs by specifying the bank number. Bank number one is for outputs one to 8; bank two for outputs nine to 16, and so on.

The format for calling **CtGetDigitalOutput8** is as follows:

```
ULONG CtGetDigitalOutput8 (  
    UULONG    lConnectID  
    ULONG     lBank  
    LPLONG    pValues );
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lBank

lBank is a long integer that specifies the bank number of the block of eight digital outputs.

Output Parameters

pValues

pValues points to a long integer that receives the value of the eight digital outputs.

The return value for the outputs is the bit mask of the block of eight outputs. The lower eight bits of the long integer contains the block of eight digital outputs.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetDigitalInput8, CtGetDigitalInput128, CtGetDigitalOutput128

CtGetDigitalInput128

CtGetDigitalInput128 reads the values of a block of 128 digital inputs. Using this function you can read digital inputs in groups of 128 by specifying the bank number. Bank number one is for inputs one to 128; bank two is for inputs 129 to 256, and so on.

The format for calling **CtGetDigitalInput128** is as follows:

```
ULONG CtGetDigitalInput128 (  
    ULONG      lConnectID  
    ULONG      lBank  
    DIGS_128*  pValues );
```

```
typedef ULONG DIGS_128[4];
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lBank

lBank is a long integer that specifies the bank number of the block of 128 digital inputs.

Output Parameters

pValues

pValues points to a four-element array of long integers that receives the values of the 128 digital inputs.

The values are returned in a bit mask. If there are less than 128 digital inputs in a block, zero is returned in each bit position for the undefined resources.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetDigitalInput8, CtGetDigitalOutput8, CtGetDigitalOutput128

CtGetDigitalOutput128

CtGetDigitalOutput128 reads the values of a block of 128 digital outputs. Using this function you can read digital outputs in groups of 128 by specifying the bank number. Bank number one is for outputs one to 128; bank two is for outputs 129 to 256, and so on.

The format for calling **CtGetDigitalOutput128** is as follows:

```
ULONG CtGetDigitalOutput128 (  
    ULONG      lConnectID  
    ULONG      lBank  
    DIGS_128*  pValues );
```

```
typedef ULONG DIGS_128[4];
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lBank

lBank is a long integer that specifies the bank number of the block of 128 digital outputs.

Output Parameters

pValues

pValues points to a four-element array of long integers that receives the values of 128 digital outputs.

The values are returned in a bit mask. If there are less than 128 digital outputs in a block, zero is returned in each bit position for the undefined resources.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetDigitalInput8, CtGetDigitalOutput8, CtGetDigitalInput128

Analog I/O Functions

CtGetAnalogInput

CtGetAnalogInput reads the value of an analog input.

The format for calling **CtGetAnalogInput** is as follows:

```
ULONG CtGetAnalogInput (  
    ULONG      lConnectID  
    ULONG      lAnalogIn  
    LPLONG     pValue );
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lAnalogIn

lAnalogIn is a long integer that specifies the number of the analog input.

Output Parameters

pValue

pValue points to a long integer that receives the value of the analog input.

The analog input value returned is a number from zero to 10,000.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetAnalogOutput, CtPutAnalogOutput, CtGetAnalogInput32,
CtGetAnalogOutput32

CtGetAnalogOutput

CtGetAnalogOutput reads the value of an analog output.

The format for calling **CtGetAnalogOutput** is as follows:

```
ULONG CtGetAnalogOutput (  
    ULONG      lConnectID  
    ULONG      lAnalogOut  
    LPLONG     pValue );
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lAnalogOut

lAnalogOut is a long integer that specifies the number of the analog output.

Output Parameters

pValue

pValue points to a long integer that receives the value of the analog output.

The analog output value returned is a number from zero to 10,000.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetAnalogInput, CtPutAnalogOutput, CtGetAnalogInput32,
CtGetAnalogOutput32

CtPutAnalogOutput

CtPutAnalogOutput writes a value to an analog input. You can specify a value from zero to 10,000.

The format for calling **CtPutAnalogOutput** is as follows:

```
ULONG CtPutAnalogOutput (  
    ULONG      lConnectID  
    ULONG      lAnalogOut  
    ULONG      lValue );
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lAnalogOut

lAnalogOut is a long integer that specifies the number of the analog output.

lValue

lValue is a long integer that specifies the value to write to the analog output .

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetAnalogInput, CtGetAnalogOutput, CtGetAnalogInput32,
CtGetAnalogOutput32

CtGetAnalogInput32

CtGetAnalogInput32 reads the values of a contiguous block of 32 analog inputs. Using this function you can read analog inputs in groups of 32 by specifying the bank number. Bank number one is for inputs one to 32; bank two for inputs 33 to 64, and so on.

The format for calling **CtGetAnalogInput32** is as follows:

```
ULONG CtGetAnalogInput32 (  
    ULONG      lConnectID  
    ULONG      lBank  
    ANGS_32*   pValues );
```

```
typedef ULONG ANGS_32[32];
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lBank

lBank is a long integer that specifies the number of the analog input bank.

Output Parameters

pValues

pValues points to a 32-element array of long integers that receives the values of the block of 32 analog inputs.

If there are less than 32 analog inputs in a block, zero is returned for the undefined resources.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetAnalogInput, CtPutAnalogOutput, CtPuttAnalogOutput,
CtGetAnalogOutput32

CtGetAnalogOutput32

CtGetAnalogOutput32 reads the values of a contiguous block of 32 analog outputs. Using this function you can read analog outputs in groups of 32 by specifying the bank number. Bank number one is for outputs one to 32; bank two for outputs 33 to 64, and so on.

The format for calling **CtGetAnalogOutput32** is as follows:

```
ULONG CtGetAnalogOutput32 (  
    ULONG      lConnectID  
    ULONG      lBank  
    ANGS_32*   pValues );
```

```
typedef ULONG ANGS_32[32];
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lBank

lBank is a long integer that specifies the number of the analog output bank.

Output Parameters

pValues

pValues points to a 32-element array of long integers that receives the values of the block of 32 analog outputs.

If there are less than 32 analog outputs in a block, zero is returned for the undefined resources.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetAnalogInput, CtPutAnalogOutput, CtPuttAnalogOutput,
CtGetAnalogInput32

Servo Functions

CtGetServoPosition

CtGetServoPosition reads the current position of a servo. You can specify a servo number from one to 16.

The format for calling **CtGetServoPosition** is as follows:

```
ULONG CtGetServoPosition (  
    ULONG      lConnectID  
    ULONG      lServo  
    LPLONG     pValue );
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lServo

lServo is a long integer that specifies the servo number.

Output Parameters

pValue

pValue points to a long integer that receives the value of the servo position.

The servo position value can range from -2,147,483,647 to 2,147,483,647.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetServoError, CtGetServoInputs

CtGetServoError

CtGetServoError reads the current error of a servo. You can specify a servo number from one to 16.

The format for calling **CtGetServoError** is as follows:

```
ULONG CtGetServoError (  
    ULONG      lConnectID  
    ULONG      lServo  
    LPLONG     pValue );
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lServo

lServo is a long integer that specifies the servo number.

Output Parameters

pValue

pValue points to a long integer that receives the value of the servo error.

The servo error value can range from -2,147,483,647 to 2,147,483,647.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetServoPosition, CtGetServoInputs

CtGetServoInputs

CtGetServoInputs reads the value of servo inputs. You can specify a servo number from one to 16.

The format for calling **CtGetServoInputs** is as follows:

```
ULONG CtGetServoInputs (  
    ULONG      lConnectID  
    ULONG      lServo  
    LPLONG     pValue );
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lServo

lServo is a long integer that specifies the servo number.

Output Parameters

pValue

pValue points to long integer that receives the value of the servo inputs.

The returned value is a bit mask of the inputs of the servo where:

- Bit 0 = Not used
- Bit 1 = Home
- Bit 2 = Start
- Bit 3 = Kill Command
- Bit 4 = Reverse Limit
- Bit 5 = Forward Limit
- Bit 6 = Index
- Bits 7 to 31 = Not used/reserved for future use

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetServoPosition, CtGetServoError

Data Table Functions

CtGetDataTableDim

CtGetDataTableDim reads the dimensions of the data table. If no data table exists, the return values are zero.

The format for calling **CtGetDataTableDim** is as follows:

```
ULONG CtGetDataTableDim (  
    ULONG      lConnectID  
    LPLONG    pRows  
    LPLONG    pCols );
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

Output Parameters

pRows

pRows points to a long integer that receives the number of rows in the data table.

pCols

pCols points to a long integer that receives the number of columns in the data table.

Value Returned

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetDataTableLoc, CtPutDataTableLoc, CtGetDataTableRow,
CtPutDataTableRow

CtGetDataTableLoc

CtGetDataTableLoc reads a value at a location in the data table.

The format for calling **CtGetDataTableLoc** is as follows:

```
ULONG CtGetDataTableLoc (  
    ULONG      IConnectID  
    ULONG      IRows  
    ULONG      ICols  
    LPLONG     pValue );
```

Input Parameters

IConnectID

IConnectID is a long integer that specifies the connection to use.

IRows

IRows is a long integer that specifies the row location in the data table.

ICols

ICols is a long integer that specifies the column location in the data table.

Output Parameters

pValue

pValue points to a long integer that receives the value from the specified location in the data table.

The returned value is a number from 0 to 65535.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetDataTableDim, CtPutDataTableLoc, CtGetDataTableRow,
CtPutDataRow

CtPutDataTableLoc

CtPutDataTableLoc writes a value to a location in the data table.

The format for calling **CtPutDataTableLoc** is as follows:

```
ULONG CtPutDataTableLoc (  
    ULONG      IConnectID  
    ULONG      IRows  
    ULONG      ICols  
    ULONG      IValue );
```

Input Parameters

IConnectID

IConnectID is a long integer that specifies the connection to use.

IRows

IRows is a long integer that specifies the row location in the data table.

ICols

ICols is a long integer that specifies the column location in the data table.

IValue

IValue is a long integer that specifies the value in the data table.

Allowable values for *IValue* are numbers from 0 to 65535.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetDataTableDim, CtGetDataTableLoc, CtGetDataTableRow,
CtPutDataTableRow

CtGetDataTableRow

CtGetDataTableRow reads the values in a data table row. You must specify a starting location in the data table.

The format for calling **CtGetDataTableRow** is as follows:

```
ULONG CtGetDataTableRow (  
    ULONG          lConnectID  
    ULONG          lRow  
    ULONG          lCol  
    ULONG          lNumCols  
    CT_DT_ROW*    pValues );
```

```
Typedef struct {  
    ULONG          lRow;  
    ULONG          lColumns[255];  
} CT_DT_ROW;
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lRow

lRows is a long integer that specifies the row location in the data table.

lCol

lCols is a long integer that specifies the column location in the data table.

lNumCols

lNumCols is a long integer that specifies the number of columns of data to read from the data table. It can be any number between one and 255.

Output Parameters

pValues

pValues points to a structure that holds the data read from the data table.

The structure contains the data returned from the *lRow* row. Only the data beginning with the *lcol* columns and extending from the *lNumCols* columns (or until the last column in the data table) are updated in the structure.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetDataTableDim, CtGetDataTableLoc, CtPutDataTableLoc,
CtPutDataTableRow

CtPutDataTableRow

CtPutDataTableRow writes values to a row in a controller's data table. You must specify a starting location within the bounds of the data table.

The format for calling **CtPutDataTableRow** is as follows:

```
ULONG CtPutDataTableRow (  
    ULONG          lConnectID  
    ULONG          lRow  
    ULONG          lCol  
    ULONG          lNumCols  
    CT_DT_ROW *   pValues );
```

```
Typedef struct {  
    ULONG          lRow;  
    ULONG          lColumns[255];  
} CT_DT_ROW;
```

Input Parameters

lConnectID

lConnectID is a long integer that specifies the connection to use.

lRow

lRow is a long integer that specifies the row location in the data table.

lCol

lCol is a long integer that specifies the column location in the data table.

lNumCols

lNumCols is a long integer that specifies the number of columns of data to write to the data table. It can be any number between one and 255.

pValues

pValues points to a structure that holds the data to write to the data table.

The structure contains the data to write in the *lRow* row. Only the data beginning with *lcol* column and extending for *lNumCols* columns (or until the last column in the data table) are written.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetDataTableDim, CtGetDataTableLoc, CtPutDataTableLoc, CtPutDataTableRow

Controller Status Functions

CtGetStatus

CtGetStatus reads the controller status.

The format for calling **CtGetStatus** is as follows:

```
ULONG CtGetStatus (  
    ULONG      lConnectID  
    LPLONG     pValue );
```

Input Parameters

lConnectID

lConnectID is a long integer value that specifies the connection to use.

Output Parameters

pValue

pValue points to a long integer that receives the value of the controller status.

The returned value is a bit mask of the controller status where:

- Bit 0 = 0 if running, 1 if stopped
- Bit 1 = 0 if normal mode, 1 if programming mode
- Bit 2 = 0 if status OK., 1 if software fault
- Bit 3 = 0 if mid-program, 1 if fresh reset
- Bit 4 to 31 are reserved for future use.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtPutStatus, CtGetTaskBank

CtPutStatus

CtPutStatus sets the controller status.

The format for calling **CtPutStatus** is as follows:

```
ULONG CtPutStatus (  
    ULONG      IConnectID  
    ULONG      IValue );
```

Input Parameters

IConnectID

IConnectID is a long integer value that specifies the connection to use.

IValue

IValue is a long integer that specifies the value of the controller status.

Specify the status value as a bit mask where:

Bit 0 = 1 to start controller, 0 to stop controller

Bit 1 = 0 (required)

Bit 2 = 0 (required)

Bit 3 = 1 to reset controller, otherwise 0

Bit 4 to 31 = 0 (required)

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetStatus, CtGetTaskBank

CtGetTaskBank

CtGetTaskBank reads a program status task bank from the controller. Depending on the model, CTC controllers can have 16, 32, or 64 tasks running in a program. **CtGetTaskBank** can access the status of each of these tasks by reading task banks of eight tasks each.

The format for calling is **CtGetTaskBank** as follows:

```
ULONG CtGetTaskBank (  
    ULONG          lConnectID  
    ULONG          lBank  
    CT_TASK_BANK * pValues );
```

```
typedef struct {  
    ULONG    lStopped;  
    ULONG    lFaultType;  
    ULONG    lFaultStep;  
    ULONG    lFaultData;  
    ULONG    lTaskStep[8];  
    ULONG    lTaskMask1[8];  
    ULONG    lTaskMask2[8];  
} CT_TASK_BANK;
```

Input Parameters

lConnectID

lConnectID is a long integer value that specifies the connection to use.

lBank

lBank is a long integer that specifies the program task bank.

Output Parameters

pValues

pValues points to a task bank structure that receives the returned values.

Remarks

***lBank* Value**

The *lBank* value can be any number between one and four, where one returns the data for tasks one to 8; two returns the data for tasks nine to 16; etc. For CTC controllers equipped with a 2701E CPU, the *lBank* value can be any number between 65 and 72.

CT_TASK_BANK Structure

The **CT_TASK_BANK** structure returned contains the following runtime status information:

- Controller state, one if stopped, zero otherwise
- Controller fault code, if any
- Step where the fault has occurred, if any
- Data associated with the fault condition, if any
- Step number that each task is executing
- Step data for each task

The step data returned is a bit mask value of any other tasks that this task is waiting on before resuming execution. A bit value of one means that the task is waiting on the task associated with the bit number, i.e., waiting on task seven if bit seven is set.

Controller Status Functions

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetStatus, CtPutStatus

Controller Configuration Functions

CtGetModel

CtGetModel reads the controller's configuration.

The format for calling **CtGetModel** is as follows:

```
ULONG CtGetModel (  
    ULONG      lConnectID  
    LPLONG     pModel  
    BOOL *     pIsEA );
```

Input Parameters

lConnectID

lConnectID is a long integer value that specifies the connection to use.

Output Parameters

pModel

pModel points to a long integer that receives the controller model.

pIsEA

pIsEA points to a boolean that receives the controller architecture type.

Remarks

The model number returned is a value specific to the controller model. The architecture type returned is **false** for non-EA controllers, or **true** for EA controllers. EA controllers have additional internal resources and command sets not available in non-EA models.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetConfig, CtPutConfig, CtGetIoCount, CtGetMiscIoCount

CtGetConfig

CtGetConfig reads the controller configuration.

The format for calling **CtGetConfig** is as follows:

```
ULONG CtGetConfig (  
    ULONG      lConnectID  
    LPLONG    pValue );
```

Input Parameters

lConnectID

lConnectID is a long integer value that specifies the connection to use.

Output Parameters

pValue

pValue points to long integer that receives the configuration value.

The returned value is a bit mask of the controller configuration where:

Bit 0 = 1 if using input 1 for START function, 0 otherwise

Bit 1 = 1 if using input 2 for STOP function, 0 otherwise

Bit 2 = 1 if using input 3 for RESET function, 0 otherwise

Bit 3 = 1 if using input 4 for STEP function, 0 otherwise

Bit 4 to 31 = 0

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetModel, CtPutConfig, CtGetIoCount, CtGetMiscIoCount

CtPutConfig

CtPutConfig sets the controller configuration.

The format for calling **CtPutConfig** is as follows:

```
ULONG CtPutConfig (  
    ULONG      lConnectID  
    ULONG      lValue );
```

Input Parameters

lConnectID

lConnectID is a long integer value that specifies the connection to use.

lValue

lValue is a long integer that sets the value of the controller configuration.

The configuration value is a bit mask where:

Bit 0 = 1 to using input 1 for START function, 0 otherwise
Bit 1 = 1 to using input 2 for STOP function, 0 otherwise
Bit 2 = 1 to using input 3 for RESET function, 0 otherwise
Bit 3 = 1 to using input 4 for STEP function, 0 otherwise
Bit 4 to 31 = 0

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetModel, CtGetConfig, CtGetIoCount, CtGetMiscIoCount

CtGetIoCount

CtGetIoCount reads the controller's basic hardware configuration. The function returns values listing the number of flags, digital inputs, digital outputs, stepping motors, servo motors, analog inputs, and analog outputs installed in the controller.

The format for calling **CtGetIoCount** is as follows:

```
ULONG CtGetIoCount (
    ULONG          IConnectID
    CT_IO_COUNT *  pValue );
```

```
Typedef struct {
    ULONG    IFlags;
    ULONG    IDigitalInputs;
    ULONG    IDigitalOutputs;
    ULONG    ISteppingMotors;
    ULONG    IServoMotors;
    ULONG    IAnalogInputs;
    ULONG    IAnalogOutputs;
} CT_IO_COUNT;
```

Input Parameters

IConnectID

IConnectID is a long integer value that specifies the connection to use.

Output Parameters

pValue

pValue points to a structure that receives the basic hardware configuration information.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetModel, CtGetConfig, CtPutConfig, CtGetMiscIoCount

CtGetMiscIoCount

CtGetMiscIoCount reads the controllers extended hardware configuration. The function returns values listing the number of prototype boards, high speed counters, four-digit thumbwheels, and four-digit numeric displays installed in the controller.

The format for calling is as follows:

```
ULONG CtGetMiscIoCount (
    ULONG          lConnectID
    CT_MISC_IO_COUNT * pValue );
```

```
typedef struct {
    ULONG          lPrototypes;
    ULONG          lHighSpeedCounters;
    ULONG          lThumbwheels;
    ULONG          lDisplays;
} CT_MISC_IO_COUNT;
```

Input Parameters

lConnectID

lConnectID is a long integer value that specifies the connection to use.

Output Parameters

pValue

pValue points to a structure that receives the extended hardware configuration information.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetModel, CtGetConfig, CtPutConfig, CtGetIoCount

Programming Functions

CtDownload

CtDownload downloads an object file into the controller. The function returns values listing the number of steps, bytes, errors, and warnings in the object file downloaded to the controller.

The format for calling **CtDownload** is as follows:

```
ULONG CtDownload (  
    ULONG lConnectID  
    CONST CHAR FAR * pObjFile  
    CT_PROG_COUNT * pCounts );
```

```
Typedef struct {  
    ULONG lSteps;  
    ULONG lBytes;  
    ULONG lErrors;  
    ULONG lWarnings;  
} CT_PROG_COUNT;
```

Input Parameters

lConnectID

lConnectID is a long integer value that specifies the connection to use.

pObjFile

pObjFile points to the object file to be downloaded.

Output Parameters

pCounts

pCounts points to a structure that receives the object file information.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtUpload

CtUpload

CtUpload uploads the controllers program to an object file. The function returns values listing the number of steps, bytes, errors, and warnings in the object file downloaded to the controller.

The format for calling **CtUpload** is as follows:

```
ULONG CtGetMiscIoCount (  
    ULONG IConnectID  
    CONST CHAR FAR * pObjFile  
    CT_PROG_COUNT * pCounts );
```

```
Typedef struct {  
    ULONG ISteps;  
    ULONG IBytes;  
    ULONG IErrors;  
    ULONG IWarnings;  
} CT_PROG_COUNT;
```

Input Parameters

IConnectID

IConnectID is a long integer value that specifies the connection to use.

pObjFile

pObjFile points to the object file to be uploaded.

Output Parameters

pCounts

pCounts points to a structure that receives the object file information.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtDownload

Miscellaneous Functions

CtGetConnectionInfo

CtGetConnectionInfo returns information on the connection. It lists the connection type, the connection time out value, and ?????? **What do some of the other Typedef parameters mean? I could use the info here.**

The format for calling **CtGetConnectionInfo** is as follows:

```
ULONG CtGetConnectionInfo (  
    EULONG          lConnectID  
    CT_CONN_INFO *  pConnInfo );
```

```
Typedef struct {  
    ULONG          lConnType;  
    ULONG          lSrcAddr;  
    ULONG          lDestAddr;  
    ULONG          lTimeout;  
    BOOL           fConnected;  
    BYTE           srcEAddr[6];  
    BYTE           destEAddr[6]  
} CT_CONN_INFO;
```

Input Parameters

lConnectID

lConnectID is a long integer value that specifies the connection to use.

Output Parameters

pConnInfo

pConnInfo points to a structure that receives the connection information.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetMessageInfo, CtGetErrorInfo

CtGetMessageInfo

CtGetMessageInfo returns information on the last message sent and last response received for the connection. The messages retrieved can have a length of 256 characters.

The format for calling **CtGetMessageInfo** is as follows:

```
ULONG CtGetMessageInfo (  
    ULONG          lConnectID  
    CT_MSG_INFO *  pMsgInfo );
```

```
typedef struct {  
    ULONG    lMsgLen;  
    BYTE     sMsgbuf[256];  
    ULONG    lRspLen;  
    BYTE     sRspbuf[256];  
} CT_MSG_INFO;
```

Input Parameters

lConnectID

lConnectID is a long integer value that specifies the connection to use.

Output Parameters

pMsgInfo

pMsgInfo points to a structure that receives the message information.

Value Returned

The **CT_MSG_INFO** structure returned contains the message data for the connection.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetConnectionInfo, CtGetErrorInfo

CtGetErrorInfo

CtGetErrorInfo returns information on the last error condition for the connection. The error message returned can have a length of 256 characters.

The format for calling **CtGetErrorInfo** is as follows:

```
ULONG CtGetErrorInfo (
    ULONG          lConnectID
    CT_ERR_INFO *  pError );
```

```
Typedef struct {
    ULONG          lCode;
    CHAR          bMessage[256];
} CT_ERR_INFO;
```

Input Parameters

lConnectID

lConnectID is a long integer value that specifies the connection to use.

Output Parameters

pError

pError points to a structure that receives the error information.

Success/Error Return Values

If the function succeeds, the return value is one. If the function fails, the return value is zero. Extended error information can be acquired by calling the **CtGetErrorInfo** function.

Other Related Functions

CtGetConnectionInfo, CtGetMessageInfo